

Alarm / Fire suppression:

- Total Fire and Omega will be here on February 20th to try and fix the outdoor fire alarm.
- On 2/20/2025 Total Fire and Omega electric spent four hours trouble shooting the outdoor horn and strobe issue. The proposed solution to fix the issue is to install
 - Altronix power supply
 - Horn/Strobe 12/24-volt red multi-candela 15,15
 - With Labor and supplies would cost \$ 988.00 this should be corrected in the first part of March.
 - March 4, 2025, Andrew from Total Fire spent about four hours installing the new outdoor horn and strobe light, which involved running new wiring from outside to the flow switch. The power for the system comes from the old facilities office, where it's plugged into an outlet but secured to prevent any risk of it falling out and triggering a false alarm.

D.N.M.H :

- We will be adding two springs to the hay bale box to help reduce the slamming of the box.
- All building permits have been signed off as of 2/24/2025
- Made the hay box so it will not slam down. Also put new rope on it because the rope was cut by the pully over the weekend. I put a couple extra wraps of rope on it, maybe it won't get cut this time. If it continues to happen, we may have to put a rubber gromet in the hole where the rope runs through

Great lakes and fisheries:

- Sat in on a meeting with Good Design on February 19th to go over the exhibit layout.
- We have to add one more staircase to the steps going up to the lab area before we can get a final sign off on the construction per Chris city building inspector.

HVAC system:

- Replaced all water filters on the R.O. system and cleaned the humidifier.

Memberships

- Breakdown of past due memberships
- 2022 = 9
- 2023 =77
- 2024 = 140
- 2025 = 15 for the first three months

- **The month of February**
- We sent out 11 Renewal letters.
- 11 past due members renewed
- 7 New members
- 6 renewed on time

Other:

- Replaced two sink faucets and drains in the women's lower restroom.
- Painted the front part of the front counter facing the gift store cloud cover white.
- The new owner of Serv pro stopped in to introduce herself.
- Replaced two ballasts in light fixtures
- Korbin.is coming in on Mondays, Wednesday, and Friday for about three hours at a time to volunteer with cleaning and other projects as needed. Korbin is volunteering to complete one hundred hours he needs for the early college program.

Up Coming Yearly test

- Our CSD-1 test is due March 1st, 2024, for the boiler system. They charge. \$1600
- The state inspector will be here March 1st, 2025, for the boiler system.
- The state elevator inspector will be here in July 2025
- Annual Fire Sprinkler test 12-2025
- 5-year internal Fire sprinkler test 2027
- 10-year sprinkler head test will be 2032
- Schindler contract expires 2038

Thank you,

Matt Klimczak