

Facilities February 2023

Other stuff: Weinkauf Plumbing will be coming over to give an estimate on fixing a roof drainpipe that is leaking into our permanent collection room. We typically use Lakeshore plumbing but they have failed twice now to come over and give an estimate. The pipe is leaking around the threads, and it is original to the building so I am not sure how much they will need to be replaced.

Computers:

The museum purchased 4 new desk top towers. The last ones we had were well over ten years old and those were upgraded from windows xp to windows 10. The new towers went to the Director, Front desk, Collections and Facilities. Johnathan will need a replacement laptop by 2025. The two computers in the collection processing room, we will use them until they no longer work. They only need to have an internet connection.

Avenue Shops:

Trelfa Gallery:

Meridian contracting:

Church:

Cabin:

Wilson G:

D.N.M.H :

A temporary wall with a four-foot door has been installed at the front of the gallery. Demolition has begun. All the paneling and furring strips were removed from the walls. Also, the artifacts that are being used in the new exhibit have been removed. The next process will be removing the rest of the artifacts to be put into permanent storage. The paneling that was on the wall was donated to two individuals. Alpena Glass is interested in the glass from the cases, and we will also try to find someone that would like the display cases, so they do not end up in the trash.

Kat v:

Chinook:

Ground Care:

HVAC system:

Up Coming Yearly test

- Our CSD-1 test is due March 1st, 2023, for the boiler system. They charge. \$ 70.00 an hour.
- The state inspector will be here March 1st, 2025, for the boiler system.
- The state elevator inspector will be here in July 2023
- Annual Fire Sprinkler test 12-2023
- 5-year internal Fire sprinkler test 2027
- 10-year sprinkler head test will be 2032

Thank you,

Matt Klimczak

