

April 17,2018

Facility Report for April

I called Mike Bobrowski owner of Air & Energy based out of Traverse City. I asked him about an audit on our system to control the humidity. It would cost us \$2500.00 to have him come over and go through the whole system to make sure everything is working properly. His suggestion is to have the exact humidity ranges we are looking for in each room. Some changes may be possible when they are here. It is also possible to add more zoning controls, but this is not included in the price. With the talk of moving the collections around It would be best to wait until we know exactly what we are looking for.

Jim from Central Station Security visited the museum on Wednesday April 11th to do a walk-through of our building. He was invited here because of the possibility of relocating the collection rooms. The first part was to upgrade our alarm panel because it could not handle the extra sensors that will be needed. The new panel will also eliminate one more phone line. The new panel will run off the cell towers. When he submits his quote, it will be in two phases, the first one will be the panel, the second one will be the sensors.

Brian from Lake Shore Plumbing and Heating also came in to do our CSD1 test on the boilers. When doing the test, we had to replace two shut off valves that started to leak after the test was completed. Everything else checked out ok.

I have spoken to Mick from Schindler elevator about the installation of the hydraulic jack. From what the manufacture is telling them we could be looking at an install date of mid-May. Mick is going to keep in contact with the manufacture to try and get it sooner. He will e-mail or call with any updates for this project.

Thankyou,

Matt Klimczak